



**SOLANO COUNTY**  
**Department of Resource Management**  
Public Works Engineering  
675 Texas Street, Suite 5500  
Fairfield, CA 94533  
www.solanocounty.com

Telephone No.: (707) 784-6765  
Fax No.: (707) 784-2894

Birgitta Corsello, Director  
Cliff Covey, Assistant Director

---

**MEMORANDUM**

**DATE:** March 12, 2010

**TO:** Nedzlene Ferrario,

  
**FROM:** Nick Burton

**SUBJECT:** U-09-13, Northern CO2 Reduction Project

Public Works Engineering has reviewed the revised plans submitted for U-09-13. The "Cost Estimate for the Closure and Restoration of the Pilot Study" is missing two items. It does not include the cost to cap and abandon the well and it does not include the cost to off haul the spoils from the drilling. Once these items are included I am requesting that the EPA comment to verify the estimated costs.

Revision C of the conceptual grading plan does not include a sump area. The sump area is a designated place for the spoils and also contains the storm water runoff. Without the sump the storm water backs up onto the pad and could possibly spill over the perimeter berm.

---

Building & Safety  
David Cliche  
Chief Building  
Official

Planning Services  
Mike Yankovich  
Program Manager

Environmental Health  
Terry Schmidtbauer  
Program Manager

Administrative  
Services  
Suganthi Krishnan  
Senior Staff Analyst

Public Works  
Engineering  
Paul Wiese  
Engineering Manager

Public Work  
Operations  
Rick O'Neill  
Operations Manager